

# DVGW certificate of conformity hygiene

## DVGW-Konformitätsbestätigung Hygiene

**HW-1002DQ0158**  
Registration Number  
Registriernummer

<b>Confirmation of Conformity</b> <i>Konformitätsbestätigung</i>	system 1+ with audit testing <i>System 1+ mit Fremdüberwachung</i>
<b>Owner of certificate</b> <i>Zertifikatinhaber</i>	KONTI HIDROPLAST Str. Industriska No. 5, MK-1480 Gevgelija
<b>Manufacturer</b> <i>Hersteller</i>	KONTI HIDROPLAST Str. Industriska No. 5, MK-1480 Gevgelija
<b>Product Category</b> <i>Produktart</i>	Hygienic suitability according to system 1+: Components from plastic, product group P1 (1002)
<b>Product description</b> <i>Produktbezeichnung</i>	Polyethylene pressure pipe for drinking water supply
<b>Material/Model</b> <i>Werkstoff/Modell</i>	PE 100-RC / Monolyer pipe (Vollwandrohr)
<b>Test reports</b> <i>Prüfberichte</i>	Certification report: dated 18.03.2025 (ZGW) Report of initial inspection: 3366283 40 dated 18.03.2023 (MPD)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DVGW CERT ZP 1000 (03.09.2024) UBA KTW-BWGL (24.02.2025) DIN EN 16421 (01.05.2015)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / Aktenzeichen</i>	18.03.2030 / 22-0700-WHE

This is to confirm that, based on the DVGW CERT ZP 1000 certification programme, the product information made available, including the recipe specifications and the above-mentioned assessment report, the above-mentioned product/component meets the requirements of, and complies with, the assessment basis/guideline of the German Federal Environmental Agency mentioned under Test Specifications for the temperature range listed on the reverse.

19.03.2025 Gsr A-1/2  
Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
PE 100-RC pressure pipe	Application: drinking water supply Production method: extrusion Temperature range: cold water, up to 23 °C Material type: PE 100-RC	black monolayer pipe with blue stripes on the outside layer

The assessment reports listed under Test Reports are an integral part of the confirmation of conformity.

The confirmation of conformity is valid from date of issue and remains valid as long as the requirements listed under "Notes" are met.

#### Notes

The confirmation of conformity was issued on the condition that the raw materials used to manufacture the product or rather their composition and/or components, including the latter's manufacturer and supplier chain have been disclosed in full and no other substances are contained in the product. The validity of this document expires in the event of modifications to the composition of the product or to the processing conditions that were not coordinated with the certification body and in the event of non-compliance with the conformity requirements as well as in the event of termination of the 1+ system monitoring programme of certification body and manufacturer.

The results of our tests and the assessments apply to the test items examined and the statutory regulations valid at the time of testing. Without our express written approval, this document may only be published or reproduced in complete and unaltered form.

This confirmation of conformity is only valid in conjunction with a corresponding entry in the Internet directory of DVGW CERT GmbH (<http://www.dvgw-cert.com>). The confirmation of conformity remains the property of DVGW CERT GmbH and must be returned to DVGW CERT GmbH upon request.

#### Hints of Utilization / Remarks

##### Verwendungshinweise / Bemerkungen

PE-materials according to the list submitted to DVGW-CERT GmbH.